

26 Jan 55

**ROYAL CANADIAN AIR FORCE****FIRE EXTINGUISHER CYLINDERS  
REMOVAL FROM SERVICE**

(This EO replaces Interim EO AFMI/M4/14 dated 31 Jul 42)

1 Fire extinguisher cylinders are to be removed from service when such cylinders are:-

(a) Dented, nicked, scarred or otherwise damaged in any way so that local intensity of stress may be produced.

(b) Subjected to heat of an intensity likely to affect the original heat treatment of the cylinder.

(c) Discharged by exposure to heat.

(d) Cylinders must not be clamped in vises or other devices which will mark or tend to distort them.

2 Equipment becoming surplus by this EO is to be disposed of in accordance with CAP 16, Vol. 1, Q13/2.

ISSUED ON AUTHORITY OF THE CHIEF OF THE AIR STAFF

Prepared By:  
AMC/SACO/ACA